

## Draft Specifications

1. Supply of 43 distribution boards with the preferred dimensions of:

610mm x 380mm x 170mm, (Two distribution boards as Essential and Non Essential in a single Panel having a physical separation between them) with 20 % expansion space. They should be of a reputable brand or make consisting of 19 pieces of 2 pole and 4 pole Circuit breakers of either ABB, Legrand, MG or an equally approved brand complete with neutral and earth bars.

2. Supply of 33 distribution boards with preferred dimensions of:

880mm x 600mm x 160mm, (Two distribution boards as essential and Non essential in a single panel having a physical separation between them) with 20% expansion space. They should be of reputable brand or make consisting of 13 pieces of 2 pole and 4 pole Circuit breakers of either ABB, Legrand, MG or an equally approved brand with neutral and earth bars..

3. Supply of Multi core cables of:-

5 X 16mm<sup>2</sup> - 2500 meters

4 X 25 mm<sup>2</sup> - 2500 meters

4 X 95mm<sup>2</sup> - 350 meters and  
single core cable of 240mm<sup>2</sup> – 100 meters.